



**EVENLITE**  
LIVES DEPEND ON US

# **SENTRY CUSTOM GRAPHICS**

---

## **INSTALLATION AND OPERATING INSTRUCTIONS**

### **IMPORTANT SAFEGUARDS**

When using electrical equipment, basic safety precautions should always be followed including the following:

### **READ AND FOLLOW ALL SAFETY INSTRUCTIONS**


1. Install in accordance with all national and local electrical codes.
2. Disconnect power at circuit breaker or fuse before installing or servicing the unit.
3. DO NOT mount in hazardous locations, near gas or near electric heaters.
4. DO NOT let power cords contact hot surfaces.
5. Equipment should be mounted in locations and at heights where it will not be readily subject to tampering by unauthorized personnel.
6. DO NOT use accessory equipment not recommended by the manufacturer. The use of such equipment may cause unsafe conditions and will void the unit's warranty.
7. DO NOT use this equipment for other than its intended purpose.
8. All servicing should be performed by qualified personnel only.
9. Allow battery to charge for 24 hours before first use.
10. For indoor use only, unless WL (Wet Location) option is selected.

### **SAVE THESE INSTRUCTIONS**

**2575 Metropolitan Drive • Trevose, PA • 19053 U.S.A**  
**Telephone: (215) 244-4204 • Fax: (215) 244-4208**


## FACEPLATE REMOVAL

Open the enclosure and separate panels using a flat blade screw driver (as shown below).



To separate the housing, insert a flat blade screwdriver into the 4 slots on the edge and rotate the blade gently so that the housing snaps apart. Repeat on all sides before pulling apart.

**FIGURE 1: Opening the Sign**



To access the rear panel, first remove this screw


To access the gear tray, remove these screws

**FIGURE 2: Removal of Screws to Open the Sign**

## KNOCKOUTS AND CHEVRONS

Support the rear panel on spacers and punch out appropriate knockouts to fix the junction box.

(For Back Mount Configuration)




**FIGURE 3: Rear Panel Knock Outs**

# TRANSFORMER WIRING

\*\*\*Before installing unit, disconnect power at breaker panel\*\*\*

**For Dual Circuit Input:** Mixed voltages may be used. (Example: 120V Utility Power, 277V Emergency Power)



## SINGLE CIRCUIT WIRING

Connect Power Receptacle to AC supply per local codes.

Black Lead for 120V or Orange Lead for 277V CAP UNUSED LEAD

White for Neutral

Green/Yellow Lead for Ground

## DUAL CIRCUIT WIRING

### IN ADDITION TO SINGLE CIRCUIT WIRING

Connect Power Receptacle to AC supply per local codes.

Red Lead for 120V or Brown Lead for 277V CAP UNUSED LEAD

Gray Lead for Neutral

Green/Yellow Lead for Ground

FIGURE 5: SINGLE CIRCUIT APPLICATION - LEAD WIRE CONNECTIONS TO TRANSFORMER

FIGURE 6: DUAL CIRCUIT APPLICATION - LEAD WIRE CONNECTIONS TO TRANSFORMER


## DUAL CIRCUIT INPUT OPTION (AC VERSIONS ONLY)

For AC versions with dual circuit input, connect power to the input wires as follows (refer to case 1 and case 2 diagrams below):


**Case 1** (Backup power is Normally On): Connect main power to input 1 and backup power to input 2.

**Case 2** (Backup power is Normally Off): Connect backup power to input 1 and main power to input 2.

### CASE 1: Backup Power is Normally On




### CASE 2: Backup Power is Normally Off



# INSTALLATION INSTRUCTIONS

## **BACK MOUNT:**


1. Remove the panels (Refer to Figure #1 and #2) and route the transformer's primary leads through the center knockout of the sign. **NOTE: When connections are being made local regulations must be followed.**
2. Connect the power plug from the sign to the power receptacle, then push it back into the junction box.
3. Ensure that the wires are routed towards the rear of the sign and are not visible when inspecting the sign from the front face.
4. Snap the front panel into place to complete the assembly process.



**FIGURE 7: BACK MOUNT ASSEMBLY (SINGLE FACE)**

## CEILING MOUNT:


1. Remove the panels (Refer to Figure #1 and Figure #2) and begin by attaching the power plug to the power receptacle and then push it back into the junction box. Install the spider plate onto the junction box.
2. Secure the spider plate firmly to the junction box. Next, route the transformer's primary leads through the top knockout of the sign.
3. Secure the canopy to the spider plate by using (2) screws supplied.
4. Remove the screw and washer holding the top plug assembly together. Then raise the sign to the canopy and ensure the sign sits flush to the canopy., Secure using canopy conduit nut ensuring it is tighten securely.
5. Ensure that the wires are not visible when inspecting the sign from the front face.
6. Snap on the front and rear panel to complete the assembly process.



**FIGURE 8: CEILING MOUNT (SINGLE OR DOUBLE FACE)**

## END MOUNT:


1. Remove the panels (Refer to Figure #1 and #2) and begin by attaching the power plug to the power receptacle and then push it back into the junction box. Install the spider plate onto the junction box.
2. Secure the spider plate firmly to the junction box.
3. Secure the canopy to the spider plate by using (2) screws supplied.
4. Remove the screw and washer holding the side plug assembly together. Next, route the transformer's primary leads through the side knockout of the sign.
5. Then raise the sign to the canopy and ensure the sign sits flush to the canopy.
6. Secure using canopy conduit nut ensuring it is tighten securely.
7. Ensure that the wires are not visible when inspecting the sign from the front face.
8. Snap on the front panel and rear panel to complete the assembly process.



**FIGURE 9: END MOUNT (SINGLE OR DOUBLE FACE)**

## **CONDUIT ENTRY MOUNT INSTALLATION (SINGLE FACE SIGN)**


1. Remove the panels (Refer to Figure #1 and Figure #2) and begin by plugging the provided wire whip into the power receptacle located in the main-frame. **NOTE: When connections are being made local regulations must be followed.**
2. Thread the conduit adapter onto the conduit (supplied by others).
3. Feed conduit nut over transformer lead inside the unit.
4. Remove the screw and washer holding the side plug assembly together. Next, route the transformer's primary leads through the side knockout of the sign.
5. Feed the transformer plug through the top or side plug and connect to wire whip.
6. Insert the sign into the conduit adapter, ensure sign sits flush to the adapter. Secure using canopy conduit nut ensuring it is tighten securely.
7. Thread on the nut to complete the assembly process.



**FIGURE 10: CONDUIT ENTRY MOUNT (SINGLE FACE)**

## HANG-Straight Pendant Mount Assembly

1. Insert pendant stem/universal joint assembly through the saddle.
2. Attach the housing to the pendant coupling with the attachment nut, set aside the assembly.
3. Affix the spider plate to the junction box.
4. Attach the saddle (from the pendant assembly) to the canopy with the provided screws.
5. Connect wires according to local codes.
6. Attach canopy to the spider plate with the provided screws.
7. Remove the top and side housing plugs and interior washers from the sign.
8. Raise the sign.
9. Snap on the front and rear covers.



**FIGURE 11: PENDANT MOUNT (SINGLE OR DOUBLE FACE)**

## FLASHER AND FIRE ALARMS

AC only signs equipped with the flasher option which will flash continuously while power is supplied.

AC only sign equipped with the FIRE ALARM SIGNAL or FLASH options will automatically flash/beep in AC mode upon application of a fire alarm signal to the BLACK & RED 22 AWG leads. The fire alarm signal can be either AC or DC of either polarity and range from 12 to 24 volts. The current draw from the fire alarm signal is less than 10 millamps.

Units that include one of the above options are intended in locations where such features are permitted by local codes. Flash rate 60/min, duty cycle: 50%

## MASTER CONFIGURATION

The self-diagnostic system "learns" the exit load when the unit reaches full charge for the first time. It is therefore necessary to have any remote exits already connected when first applying AC power. Subsequent self-tests and user-tests will compare the actual exit load to the "learned value". If the remote exit load is changed once it has been learned, it is necessary to disconnect AC power at the circuit breaker panel and unplug the internal battery. Once these are reconnected, the unit will "learn" the new exit load.

The SENII has the capability to power a Remote Lamp **OR** a low-level Exit sign, not both at the same time.

## REMOTE SIGN CONFIGURATION

The remote sign is assembled in the same manner as the master sign, without a spider plate assembly. An option connector is also installed in the remote sign for interconnection to the master sign.

Interconnect the signs with a 2-conductor cable (**22 awg minimum, supplied by contractor**), per the National Electric Code, White (Positive) and Blue (Negative) wires. The run should be a distance of 50 feet or less.

## REMOTE LAMP CONFIGURATION

To install remote lamp (3.6V,3W max - not shown), the option connector is installed similarly in the master sign as shown in (Figure 13). Terminate remote lamp leads to the option connector in mating pins labeled "Remote Lamp". Remote Lamp max mounting height to be 11ft or the equivalent.

## COMPATIBLE REMOTE LAMPS:

1. TELESIS PRW LED  
(PRWLED1MV)
2. (TCRH1)



**EVENLITE**  
LIVES DEPEND ON US

**SAVE THESE INSTRUCTIONS**

**2575 Metropolitan Drive • Trevose, PA • 19053 U.S.A**  
**Telephone: (215) 244-4204 • Fax: (215) 244-4208**