

DIMENSIONAL OUTLINE

4.2KW to 12.5KW 3P Three Phase (3P) Inverter (Electronics) Cabinet and Battery Cabinet

Power/ VA Rating (W)	No. of Batteries	Max Output Breakers
4200	8	24
5200	10	24
6250	12	24
8250	16	24
10500	20	24
12500	24	24

Note: 3P output breaker quantity should be in multiples of 3 to ensure even load distribution.

Three Phase Voltage Specification (3P)	120/208V 277/480V
--	----------------------

