

TELESIS TSCT

Connecticut Code-Compliant Steel LED Exit Sign

The Telesis TSCT is designed to comply with the State of Connecticut Building Code requirements, and provide an EXIT sign with a 6" International Symbol of Accessibility. Its classic design and the convenience of a single, integrated sign make the TSCT the ideal choice for accessibility and compliance. Now incorporating the new "dynamic character leaning forward" symbol as required in Substitute House Bill No. 5050, Public Act No. 16-78 "An Act of Modernizing the Symbol of Access for Persons with Disabilities".



CONSTRUCTION

- White powder coated steel finish is standard with Black to order
- Universal mounting canopy included for ceiling mounting, or end mounting, single or double face to order
- Universal mounting pattern is stamped into the back plate for easy surface mounting to a j-box
- Matching 6" EXIT sign available, order as TS

ELECTRICAL

- Push to test switch and AC present indicator provided on EM models
- Long life Nickel Cadmium maintenance free battery provides the required 90 minutes of emergency operation
- Operating temperature range 10°C to 45°C
- Optional 2 hour battery is available
- Field Selectable 120 or 277 VAC input
- Integral AC Present Indicator and Push to Test Switch, EM Models
- Solid state transfer relay ensures reliability, no relay contacts to oxidize and fail
- Electronic Control Circuit provides current control and circuit protection ensuring optimum LED efficiency and life

ILLUMINATION

- Maintenance free LED light source with low energy consumption <5 watts and long life
- Field selectable chevron directional indicators
- Red or Green LED's with 6" letter and 3/4" stroke and 6" International Symbol of Accessibility

CERTIFICATION

- UL 924 listed, meets Connecticut Building Code, NFPA 101 Life Safety Code, NFPA 70-NEC and OSHA requirements
- Buy American Act compliant

COMPLIANCE

- 1011.2.1.2 Accessible Exits:** Where exit signs are required by Section 1011.1 of this code, accessible exit doors at the level of exit discharge that lead directly to the accessible paths of exit discharge shall additionally be marked by the International Symbol of Accessibility. Such symbol shall be not less than 6 inches high and shall be incorporated into the required exit sign or shall be located adjacent to it. Such symbol shall meet the requirements of Section 1011.

WARRANTY

- 3 year limited warranty - view complete warranty terms online at www.evenlite.com/terms-warranty.

ORDERING GUIDE

TSCT-EM-R-U-W

MODEL	OPERATION	LETTER COLOR	FACE COUNT	HOUSING COLOR	OPTIONS	ORDERING NOTES
TSCT	AC AC Only (120/277V)	R Red LED	U Universal	W White (Standard)	B Black Housing and Canopy	1 Dimensions: 19.5"W x 13"H x 4.5"D
	EM Nickel Cadmium battery backup	G Green LED			2H 2 Hour Emergency Operation	
TSCT			U	W	WG70 Wireguard for TSCT ¹ TP Tamper-proof screws	

Fill in fields from categories above and complete type and part number.

Type No:

Full Part No:

DIMENSIONS



FACEPLATE

Faceplate slides up and outward for quick and easy installation

